

CLIENT INFORMANTION

Name: Hoosic Valley Central School District
Address: 2 Pleasant Ave, Schaghticoke, NY 12154
Client Rep: Anthony Cammarata (518) 753-4458 ext 1502

Date of Sampling:	Various
Samples Taken By:	District Staff and Questar III BOCES

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Elementary School
BLDG ADDRESS: 22 Pleasant Ave, Schaghticoke, NY 12154
CONTACT NAME & NUMBERS: Anthony Cammarata (518) 753-4458 ext 1502

(1) Yr. Built
1959

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information							
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Sample Date	Initial/Resample
1	ES-01-CF-P-01	52	Sink Faucet			X	5:03	23.8	400	9/16/2016	Initial
R1	ES-01-CF-R-01	52	Sink Faucet			X	5:50	9	N/A	2/3/2017	Resample
2	ES-01-DW-P-02	52	Bubbler			X	5:03	0.87	30	9/16/2016	Initial
R2	ES-01-DW-R-02	52	Bubbler			X	5:50	7	N/A	2/3/2017	Resample
3	ES-01-CF-P-03	50	Sink Faucet			X	5:07	28.4	300	9/16/2016	Initial
R3	ES-01-CF-R-03	50	Sink Faucet			X	5:52	5	N/A	2/3/2017	Resample
4	ES-01-CF-P-04	50	Sink Faucet			X	5:07	5.91	100	9/16/2016	Initial
R4	ES-01-CF-R-04	50	Sink Faucet			X	5:52	13	N/A	2/3/2017	Resample
5	ES-01-DW-P-05	50	Bubbler			X	5:07	6.02	100	9/16/2016	Initial
6	ES-01-BF-P-06	Corridor 50	Bathroom Faucet			X	5:00	1.4	100	9/16/2016	Initial
7	ES-01-BF-P-07	Corridor 49	Bathroom Faucet			X	5:10	0.61	90	9/16/2016	Initial
8	ES-01-CF-P-08	51	Sink Faucet			X	5:11	3.32	200	9/16/2016	Initial
9	ES-01-CF-P-09	51	Sink Faucet			X	5:12	5.08	200	9/16/2016	Initial
10	ES-01-DW-P-10	51	Bubbler			X	5:12	3.08	70	9/16/2016	Initial
11	ES-01-CF-P-11	55	Sink Faucet			X	5:14	1.48	200	9/16/2016	Initial
12	ES-01-DW-P-12	55	Bubbler			X	5:15	0.71	40	9/16/2016	Initial
13	ES-01-CF-P-13	57	Sink Faucet			X	5:15	3.36	70	9/16/2016	Initial
14	ES-01-DW-P-14	57	Bubbler			X	5:15	2.51	70	9/16/2016	Initial
15	ES-01-BF-P-15	Boy's Restroom	Bathroom Faucet			X	5:16	6.22	200	9/16/2016	Initial
16	ES-01-BF-P-16	Boy's Restroom	Bathroom Faucet			X	5:16	3.92	100	9/16/2016	Initial
17	ES-01-BF-P-17	Boy's Restroom	Bathroom Faucet			X	5:16	8.35	200	9/16/2016	Initial
18	ES-01-BF-P-18	Girl's Restroom	Bathroom Faucet			X	5:17	14.8	200	9/16/2016	Initial
R18	ES-01-BF-R-18	Girl's Restroom	Bathroom Faucet			X	5:56	15	N/A	2/3/2017	Resample
R18	ES-01-BF-R-18	Girl's Restroom	Bathroom Faucet			X	6:50	5	N/A	5/25/2017	Resample
19	ES-01-BF-P-19	Girl's Restroom	Bathroom Faucet			X	5:17	11.9	300	9/16/2016	Initial
R19	ES-01-BF-R-19	Girl's Restroom	Bathroom Faucet			X	5:56	10	N/A	2/3/2017	Resample
20	ES-01-BF-P-20	Girl's Restroom	Bathroom Faucet			X	6:16	15.1	528	9/16/2016	Initial
R20	ES-01-BF-R-20	Girl's Restroom	Bathroom Faucet			X	5:56	4	N/A	2/3/2017	Resample
21	ES-01-CF-P-21	59	Sink Faucet			X	5:19	3.68	80	9/16/2016	Initial
22	ES-01-DW-P-22	59	Bubbler			X	5:19	1.78	50	9/16/2016	Initial
23	ES-01-CF-P-23	61	Sink Faucet			X	6:12	147	664	9/16/2016	Initial
R23	ES-01-CF-R-23	61	Sink Faucet			X	5:58	104	N/A	2/3/2017	Resample
R23	ES-01-CF-R-23	61	Sink Faucet			X	6:52	2	N/A	5/25/2017	Resample
24	ES-01-DW-P-24	61	Bubbler			X	6:12	56.3	294	9/16/2016	Initial
R24	ES-01-DW-R-24	61	Bubbler			X	5:58	12	N/A	2/3/2017	Resample
25	ES-01-CF-P-25	63	Sink Faucet			X	5:20	9.97	200	9/16/2016	Initial

26	ES-01-DW-P-26	63	Bubbler		X	5:20	4.32	60	9/16/2016	Initial
27	ES-01-CF-P-27	65	Sink Faucet		X	5:23	5.92	100	9/16/2016	Initial
R27	ES-01-CF-R-27	65	Sink Faucet		X	6:00	8	N/A	2/3/2017	Resample
28	ES-01-DW-P-28	65	Bubbler		X	5:23	198	50	9/16/2016	Initial
R28	ES-01-DW-R-28	65	Bubbler		X	6:00	6	N/A	2/3/2017	Resample
29	ES-01-CF-P-29	67	Sink Faucet		X	5:23	ND	100	9/16/2016	Initial
30	ES-01-DW-P-30	67	Bubbler		X	5:23	ND	70	9/16/2016	Initial
31	ES-01-CF-P-31	69	Sink Faucet		X	5:25	ND	200	9/16/2016	Initial
32	ES-01-DW-P-32	69	Bubbler		X	5:25	ND	80	9/16/2016	Initial
33	ES-01-CF-P-33	66	Sink Faucet		X	5:26	0.54	200	9/16/2016	Initial
34	ES-01-DW-P-34	66	Bubbler		X	5:26	ND	100	9/16/2016	Initial
35	ES-01-CF-P-35	64	Sink Faucet		X	5:27	0.89	200	9/16/2016	Initial
36	ES-01-DW-P-36	64	Bubbler		X	5:27	ND	70	9/16/2016	Initial
37	ES-01-BF-P-37	Boy's Restroom 62	Bathroom Faucet		X	5:29	0.78	200	9/16/2016	Initial
38	ES-01-BF-P-38	Girl's Restroom 62	Bathroom Faucet		X	5:29	1.23	100	9/16/2016	Initial
39	ES-01-CF-P-39	60	Sink Faucet		X	5:29	8.21	100	9/16/2016	Initial
40	ES-01-DW-P-40	60	Bubbler		X	5:30	1.94	100	9/16/2016	Initial
41	ES-01-CF-P-41	58	Sink Faucet		X	5:32	3.79	100	9/16/2016	Initial
42	ES-01-DW-P-42	58	Bubbler		X	5:32	1.21	80	9/16/2016	Initial
43	ES-01-CF-P-43	56	Sink Faucet		X	5:32	3.24	80	9/16/2016	Initial
44	ES-01-DW-P-44	56	Bubbler		X	5:33	1.16	80	9/16/2016	Initial
45	ES-01-BF-P-45	Boiler Restroom	Bathroom Faucet		X	5:35	ND	60	9/16/2016	Initial
46	ES-01-DW-P-46	Corridor Boiler	Water Fountain		X	5:36	0.8	30	9/16/2016	Initial
47	ES-01-DW-P-47	Boy's Locker Room	Water Fountain		X	5:37	0.63	50	9/16/2016	Initial
48	ES-01-BF-P-48	Boy's Locker Room	Bathroom Faucet		X	5:37	0.62	90.9	9/16/2016	Initial
49	ES-01-DW-P-49	Girl's Locker Room	Water Fountain		X	5:28	3.75	90	9/16/2016	Initial
50	ES-01-BF-P-50	Girl's Locker Room	Bathroom Faucet		X	5:39	ND	90	9/16/2016	Initial
51	ES-01-CF-P-51	47	Sink Faucet		X	5:40	ND	200	9/16/2016	Initial
52	ES-01-DW-P-52	47	Bubbler		X	5:41	ND	80	9/16/2016	Initial
53	ES-01-CF-P-53	45	Sink Faucet		X	5:42	ND	100	9/16/2016	Initial
54	ES-01-DW-P-54	45	Bubbler		X	5:42	ND	90	9/16/2016	Initial
55	ES-01-CF-P-55	43	Sink Faucet		X	5:43	0.76	200	9/16/2016	Initial
56	ES-01-DW-P-56	43	Bubbler		X	5:43	ND	50	9/16/2016	Initial
R56	ES-01-DW-R-56	43	Bubbler		X	6:55	7	N/A	5/25/2017	Resample
57	ES-01-BF-P-57	Men's Restroom	Bathroom Faucet		X	5:45	0.96	100	9/16/2016	Initial
58	ES-01-BF-P-58	Men's Restroom	Bathroom Faucet		X	5:45	1.81	200	9/16/2016	Initial
59	ES-01-BF-P-59	Men's Restroom	Bathroom Faucet		X	5:45	ND	200	9/16/2016	Initial
60	ES-01-BF-P-60	Women's Restroom	Bathroom Faucet		X	5:35	7.44	685	9/16/2016	Initial
R60	ES-01-BF-R-60	AUD Women's Restroom	Bathroom Faucet		X	6:02	2	N/A	2/3/2017	Resample
61	ES-01-BF-P-61	AUD Women's Restroom	Bathroom Faucet		X	5:46	1.75	300	9/16/2016	Initial
R61	ES-01-BF-R-61	AUD Women's Restroom	Bathroom Faucet		X	6:02	0.8	N/A	2/3/2017	Resample
62	ES-01-BF-P-62	AUD Women's Restroom	Bathroom Faucet		X	5:46	31.3	500	9/16/2016	Initial
R62	ES-01-BF-R-62	AUD Women's Restroom	Bathroom Faucet		X	6:02	8	N/A	2/3/2017	Resample
63	ES-01-BF-P-63	AUD Women's Restroom	Bathroom Faucet		X	5:46	14.6	500	9/16/2016	Initial
R63	ES-01-BF-R-63	AUD Women's Restroom	Bathroom Faucet		X	6:02	20	N/A	2/3/2017	Resample
R63	ES-01-BF-R-63	AUD Women's Restroom	Bathroom Faucet		X	6:58	1	N/A	5/25/2017	Resample
64	ES-01-CF-P-64	41	Sink Faucet		X	5:47	0.91	200	9/16/2016	Initial
65	ES-01-DW-P-65	41	Bubbler		X	5:47	ND	70	9/16/2016	Initial
66	ES-01-CF-P-66	39	Sink Faucet		X	5:48	0.75	200	9/16/2016	Initial
67	ES-01-DW-P-67	39	Bubbler		X	5:48	ND	40	9/16/2016	Initial
68	ES-01-DW-P-68	Corridor 39	Water Cooler		X	5:50	1.39	70	9/16/2016	Initial
69	ES-01-DW-P-69	Corridor 39	Water Cooler		X	5:50	3.6	60	9/16/2016	Initial
70	ES-01-BF-P-70	Main Office Men's Restroom	Bathroom Faucet		X	5:50	11.3	400	9/16/2016	Initial
71	ES-01-BF-P-71	Main Office Women's Rest	Bathroom Faucet		X	5:51	0.63	200	9/16/2016	Initial
72	ES-01-CF-P-72	21 Library	Sink Faucet		X	5:52	2.96	300	9/16/2016	Initial

73	ES-01-BF-P-73	Faculty Restroom Left	Bathroom Faucet		X	6:00	2.44	80	9/16/2016	Initial
74	ES-01-SF-P-74	17 TLC	Sink Faucet		X	5:54	1.21	200	9/16/2016	Initial
75	ES-01-DW-P-75	17 TLC	Bubbler		X	5:54	3.23	100	9/16/2016	Initial
76	ES-01-BF-P-76	Faculty Restroom Right	Bathroom Faucet		X	5:54	1.44	90	9/16/2016	Initial
77	ES-01-CF-P-77	15	Sink Faucet		X	5:56	3.53	100	9/16/2016	Initial
78	ES-01-DW-P-78	15	Bubbler		X	5:58	ND	50	9/16/2016	Initial
78A	ES-01-BF-P-78A	15	Bathroom Faucet		X	5:36	97	4510	9/16/2016	Initial
R78A	ES-01-BF-R-78A	15	Bathroom Faucet		X	6:07	9	N/A	2/3/2017	Resample
R78A	ES-01-BF-R-78A	15	Bathroom Faucet		X	7:30	N/A	122	6/21/2017	Resample
79	ES-01-CF-P-79	13	Sink Faucet		X	5:58	5.16	200	9/16/2016	Initial
80	ES-01-DW-P-80	13	Bubbler		X	5:58	ND	40	9/16/2016	Initial
81	ES-01-BF-P-81	13	Bathroom Faucet		X	6:07	584	3230	9/16/2016	Initial
R81	ES-01-BF-R-81	13	Bathroom Faucet		X	6:09	1	N/A	2/3/2017	Resample
R81	ES-01-BF-R-81	13	Bathroom Faucet		X	7:33	N/A	73	6/21/2017	Resample
82	ES-01-CF-P-82	11	Sink Faucet		X	6:02	16	200	9/16/2016	Initial
R82	ES-01-CF-R-82	10	Sink Faucet		X	7:30	22	N/A	2/8/2017	Resample
R82	ES-01-CF-R-82	11	Sink Faucet		X	7:03	2	N/A	5/25/2017	Resample
83	ES-01-DW-P-83	11	Bubbler		X	6:02	0.96	60	9/16/2016	Initial
R83	ES-01-DW-R-83	11	Bubbler		X	7:30	56	N/A	2/8/2017	Resample
R83	ES-01-DW-R-83	11	Bubbler		X	7:04	16	N/A	5/25/2017	Resample
R83	ES-01-DW-R-83	11	Bubbler		X	7:25	15	N/A	6/21/2017	Resample
R83	ES-01-DW-R-83	11	Bubbler		X	7:15	1.1	115	10/18/2017	Resample
84	ES-01-BF-P-84	11	Bathroom Faucet		X	6:02	7.59	100	9/16/2016	Initial
R84	ES-01-BF-R-84	11	Bathroom Faucet		X	6:11	2	N/A	2/3/2017	Initial
85	ES-01-CF-P-85	9	Sink Faucet		X	6:03	4.61	200	9/16/2016	Initial
86	ES-01-DW-P-86	9	Bubbler		X	6:03	ND	60	9/16/2016	Initial
87	ES-01-BF-P-87	9	Bathroom Faucet		X	5:39	4.91	105	9/16/2016	Initial
88	ES-01-CF-P-88	7	Sink Faucet		X	6:04	5.15	200	9/16/2016	Initial
89	ES-01-DW-P-89	7	Bubbler		X	6:04	0.58	60.3	9/16/2016	Initial
90	ES-01-BF-P-90	7	Bathroom Faucet		X	6:06	2.04	100	9/16/2016	Initial
91	ES-01-CF-P-91	6	Sink Faucet		X	6:06	4.6	200	9/16/2016	Initial
92	ES-01-DW-P-92	6	Bubbler		X	6:06	ND	30	9/16/2016	Initial
93	ES-01-BF-P-93	6	Bathroom Faucet		X	5:41	4.31	106	9/16/2016	Initial
94	ES-01-CF-P-94	5	Sink Faucet		X	6:08	3.5	200	9/16/2016	Initial
95	ES-01-DW-P-95	5	Bubbler		X	6:10	ND	50.4	9/16/2016	Initial
96	ES-01-BF-P-96	5	Bathroom Faucet		X	5:43	45.7	532	9/16/2016	Initial
R96	ES-01-BF-R-96	5	Bathroom Faucet		X	6:13	6	N/A	2/3/2017	Resample
97	ES-01-CF-P-97	3	Sink Faucet		X	6:10	2.55	200	9/16/2016	Initial
98	ES-01-DW-P-98	3	Bubbler		X	6:10	ND	60	9/16/2016	Initial
99	ES-01-BF-P-99	3	Bathroom Faucet		X	5:56	696	12100	9/16/2016	Initial
R99	ES-01-BF-R-99	3	Bathroom Faucet		X	6:15	3	N/A	2/3/2017	Resample
R99	ES-01-BF-R-99	3	Bathroom Faucet		X	7:37	N/A	1100	6/21/2017	Resample
100	ES-01-CF-P-100	1	Sink Faucet		X	6:10	2.18	200	9/16/2016	Initial
101	ES-01-DW-P-101	1	Bubbler		X	6:12	ND	40	9/16/2016	Initial
102	ES-01-BF-P-102	1	Bathroom Faucet		X	5:47	13.1	298	9/16/2016	Initial
103	ES-01-CF-P-103	2	Sink Faucet		X	6:14	2.87	100	9/16/2016	Initial
104	ES-01-DW-P-104	2	Bubbler		X	6:14	ND	100	9/16/2016	Initial
105	ES-01-BF-P-105	2	Bathroom Faucet		X	5:49	8.23	361	9/16/2016	Initial
106	ES-01-SF-P-106	4	Sink Faucet		X	6:15	3.11	200	9/16/2016	Initial
107	ES-01-DW-P-107	4	Bubbler		X	6:15	ND	70	9/16/2016	Initial
108	ES-01-BF-P-108	4	Bathroom Faucet		X	5:49	27.2	1240	9/16/2016	Initial
R108	ES-01-BF-R-108	4	Bathroom Faucet		X	6:16	3	N/A	2/3/2017	Resample
109	ES-01-CF-P-109	8	Sink Faucet		X	6:17	6.82	200	9/16/2016	Initial
110	ES-01-DW-P-110	8	Bubbler		X	6:17	0.76	60	9/16/2016	Initial

111	ES-01-BF-P-111	8	Bathroom Faucet		X	6:22	ND	30.8	9/16/2016	Initial
112	ES-01-CF-P-112	10	Sink Faucet		X	6:19	11.6	200	9/16/2016	Initial
113	ES-01-DW-P-113	10	Bubbler		X	6:19	1.09	80	9/16/2016	Initial
114	ES-01-BF-P-114	10	Bathroom Faucet		X	6:19	3.58	100	9/16/2016	Initial
115	ES-01-BF-P-115	12	Bathroom Faucet		X	6:20	2.8	100	9/16/2016	Initial
116	ES-01-CF-P-116	14	Sink Faucet		X	6:22	2.1	100	9/16/2016	Initial
117	ES-01-BF-P-117	14	Bathroom Faucet		X	6:23	ND	100	9/16/2016	Initial
118	ES-01-SF-P-118	Kitchen	Sink Faucet		X	6:24	3.45	100	9/16/2016	Initial
119	ES-01-SF-P-119	Kitchen	Sink Faucet		X	6:24	4.38	100	9/16/2016	Initial
120	ES-01-SF-P-120	Kitchen	Sink Faucet		X	6:25	3.1	100	9/16/2016	Initial
121	ES-01-SF-P-121	Kitchen	Sink Faucet		X	6:25	2.31	200	9/16/2016	Initial
122	ES-01-SF-P-122	Kitchen	Sink Faucet		X	6:26	5.17	100	9/16/2016	Initial
123	ES-01-SF-P-123	Kitchen	Sprayer		X	6:26	ND	40.5	9/16/2016	Initial
R123	ES-01-SF-R-123	Kitchen	Sprayer		X	6:21	4	N/A	2/3/2017	Resample
124	ES-01-BF-P-124	Kitchen	Bathroom Faucet		X	6:26	1.14	100	9/16/2016	Initial
125	ES-01-DW-P-125	Cafeteria	Water Cooler		X	6:29	ND	50	9/16/2016	Initial
126	ES-01-DW-P-126	Cafeteria	Water Cooler		X	6:24	ND	100	9/16/2016	Initial
127	ES-01-CF-P-127	Art	Sink Faucet		X	6:30	1.45	100	9/16/2016	Initial
128	ES-01-CF-P-128	Art	Sink Faucet		X	6:30	3.06	500	9/16/2016	Initial
129	ES-01-CF-P-129	Art	Sink Faucet		X	6:30	3.25	90	9/16/2016	Initial

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY

Lab: CNA Environmental	
Contact: Dakota Snyder 518-884-0800 x402	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name: Hoosic Valley Central School District
Address: 2 Pleasant Ave, Schaghticoke, NY 12154
Client Rep: Anthony Cammarata (518) 753-4458 ext 1502

Date of Sampling:	Various
Samples Taken By:	District and Questar Staff

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Jr./Sr. High School
BLDG ADDRESS: 1758 Route 67, Schaghticoke, NY 12154
CONTACT NAME & NUMBERS: Anthony Cammarata (518) 753-4458 ext 1502

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information						
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	Lead	Copper	Sample Date
1	HS-01-SF-P-01	131 Guidance	Sink Faucet			X	4:56	0.51	512	
2	HS-01-NF-P-02	29 Nurse	Sink Faucet			X	4:57	0.52	748	
3	HS-01-BF-P-03	29 Nurse	Bathroom Faucet			X	4:57	ND	696	
4	HS-01-CF-P-04	30a Band/Chorus	Sink Faucet			X	4:59	5.67	125	
5	HS-01-CF-P-05	24 Technology	Sink Faucet			X	5:00	0.65	601	
6	HS-01-CF-P-06	24 Technology	Sink Faucet			X	5:00	0.56	590	
7	HS-01-CF-P-07	22 Technology	Sink Faucet			X	5:03	0.9	500	
7RS	HS-01-CF-P-07RS	22 Technology	Sink Faucet			X	6:45	1	217	Resample - lead and copper
8	HS-01-CF-P-08	22 Technology	Sink Faucet			X	5:03	ND	485	
	HS-01-CF-P-08RS	22 Technology	Sink Faucet			X	6:46	-	280	Resample - copper only
9	HS-01-CF-P-09	22 Technology	Sink Faucet			X	5:59	3	593	
10	HS-01-CF-P-10	22 Technology	Sink Faucet			X	5:03	0.95	471	
11	HS-01-BF-P-11	57	Bathroom Faucet			X	5:05	ND	374	
12	HS-01-BF-P-12	55	Bathroom Faucet			X	5:05	ND	583	
13	HS-01-DW-P-13	55/57 Fountains	Water Fountain			X	5:06	ND	236	
14	HS-01-DW-P-14	55/57 Fountains	Water Fountain			X	5:06	ND	247	
15	HS-01-BF-P-15	Restroom by 18	Bathroom Faucet			X	5:07	ND	443	
16	HS-01-BF-P-16	49 Boy's Restroom	Bathroom Faucet			X	5:08	5.19	523	
17	HS-01-BF-P-17	49 Boy's Restroom	Bathroom Faucet			X	5:08	1.86	485	
18	HS-01-IM-P-18	47a	Ice Machine			X	5:09	ND	250	
19	HS-01-BF-P-19	47 Girl's Restroom	Bathroom Faucet			X	5:10	2.08	445	
20	HS-01-BF-P-20	47 Girl's Restroom	Bathroom Faucet			X	5:10	1.3	457	
21	HS-01-SF-P-21	45 Concession	Sink Faucet			X	5:11	8.9	595	
22	HS-01-SF-P-22	45 Concession	Sink Faucet			X	5:11	0.76	471	
23	HS-01-SF-P-23	Girl's Locker Room	Sink Faucet			X	5:12	6.09	247	
24	HS-01-SF-P-24	Girl's Locker Room	Sink Faucet			X	5:12	3.91	267	
25	HS-01-SF-P-25	Boy's Locker Room	Sink Faucet			X	5:13	4.37	499	
26	HS-01-SF-P-26	Boy's Locker Room	Sink Faucet			X	5:13	3.63	584	
27	HS-01-DW-P-27	Locker RM/Gym Corridor	Water Fountain			X	5:15	ND	359	
28	HS-01-CF-P-28	17a	Sink Faucet			X	5:16	0.81	562	
29	HS-01-DW-P-29	Fountain by Gym Doors	Water Fountain			X	5:58	ND	162	
30	HS-01-BF-P-30	35b Boy's Restroom	Bathroom Faucet			X	5:17	1.39	419	

31	HS-01-BF-P-31	35b Boy's Restroom	Bathroom Faucet			X	5:17	4.85	302	
32	HS-01-BF-P-32	35b Boy's Restroom	Bathroom Faucet			X	5:17	2.69	234	
33	HS-01-BF-P-33	35b Boy's Restroom	Bathroom Faucet			X	5:17	1.35	263	
34	HS-01-BF-P-34	35a Girl's Restroom	Bathroom Faucet			X	5:17	0.98	285	
35	HS-01-BF-P-35	35a Girl's Restroom	Bathroom Faucet			X	5:19	1.24	444	
36	HS-01-BF-P-36	35a Girl's Restroom	Bathroom Faucet			X	5:19	1.74	313	
37	HS-01-CF-P-37	21 Science	Sink Faucet			X	5:19	36.3	403	Science classroom - Non-potable water lable affixed
38	HS-01-CF-P-38	21 Science	Sink Faucet			X	5:26	21.8	449	Science classroom - Non-potable water lable affixed
39	HS-01-CF-P-39	21 Science	Sink Faucet			X	5:26	69	389	Science classroom - Non-potable water lable affixed
40	HS-01-CF-P-40	21 Science	Sink Faucet			X	5:25	30.8	410	Science classroom - Non-potable water lable affixed
41	HS-01-CF-P-41	21 Science	Sink Faucet			X	5:25	95.6	329	Science classroom - Non-potable water lable affixed
42	HS-01-CF-P-42	21/23 Prep Room	Sink Faucet			X	5:25	26.9	445	Science classroom - Non-potable water lable affixed
43	HS-01-CF-P-43	23 Science	Sink Faucet			X	5:24	350	555	Science classroom - Non-potable water lable affixed
44	HS-01-CF-P-44	23 Science	Sink Faucet			X	5:29	27.3	390	Science classroom - Non-potable water lable affixed
45	HS-01-CF-P-45	23 Science	Sink Faucet			X	5:30	30.2	386	Science classroom - Non-potable water lable affixed
46	HS-01-CF-P-46	23 Science	Sink Faucet			X	5:30	52.7	344	Science classroom - Non-potable water lable affixed
47	HS-01-SF-P-47	142 Office Area	Sink Faucet			X	5:30	1.79	913	
48	HS-01-KF-P-48	Kitchen	Sink Faucet			X	5:30	1.88	372	
49	HS-01-KF-P-49	Kitchen	Sink Faucet			X	5:30	2.49	357	
50	HS-01-KF-P-50	Kitchen	Sink Faucet			X	5:36	11.9	626	
51	HS-01-KF-P-51	Kitchen	Sink Faucet			X	5:35	1.15	574	
52	HS-01-KF-P-52	Kitchen	Sink Faucet			X	5:39	5.39	717	
53	HS-01-KF-P-53	Kitchen	Sink Faucet			X	5:35	0.92	568	
54	HS-01-BF-P-54	Kitchen Restroom	Bathroom Faucet			X	5:34	ND	548	
55	HS-01-DW-P-55	Fountains by 120	Water Fountain			X	5:33	ND	462	
56	HS-01-DW-P-56	Fountains by 120	Water Fountain			X	5:33	ND	420	
57	HS-01-BF-P-57	117 Boy's Restroom	Bathroom Faucet			X	5:42	3.36	450	
58	HS-01-BF-P-58	117 Boy's Restroom	Bathroom Faucet			X	5:42	2.03	380	
59	HS-01-BF-P-59	117 Boy's Restroom	Bathroom Faucet			X	5:42	3.49	474	
60	HS-01-DW-P-60	115/117 Fountain	Water Fountain			X	5:46	1.88	633	
61	HS-01-BF-P-61	115 Faculty Womens	Bathroom Faucet			X	5:44	ND	218	
62	HS-01-BF-P-62	115 Girl's Restroom	Bathroom Faucet			X	5:44	1.92	405	
63	HS-01-BF-P-63	115 Girl's Restroom	Bathroom Faucet			X	5:49	1.6	540	
64	HS-01-BF-P-64	115 Girl's Restroom	Water Fountain			X	5:44	3.51	469	
65	HS-01-CF-P-65	101 Art	Sink Faucet			X	5:48	1.64	481	
66	HS-01-CF-P-66	101 Art	Sink Faucet			X	5:48	2.2	289	
67	HS-01-CF-P-67	101 Art	Sink Faucet			X	5:48	5.03	347	
68	HS-01-CF-P-68	101 Art	Sink Faucet			X	5:48	1.77	469	
69	HS-01-CF-P-69	101 Art	Sink Faucet			X	5:48	4.62	254	
70	HS-01-CF-P-70	101 Art	Sink Faucet			X	5:48	2.46	277	
71	HS-01-CF-P-71	101 Art	Sink Faucet			X	5:48	2.11	224	
72	HS-01-CF-P-72	102 Art	Sink Faucet			X	5:51	3.18	637	

73	HS-01-CF-P-73	102 Art	Sink Faucet		X	5:51	1.21	526	
74	HS-02-CF-P-74	102 Art	Sink Faucet		X	5:51	5.54	790	
75	HS-02-CF-P-75	203 Science	Sink Faucet		X	5:55	1.82	763	
76	HS-02-CF-P-76	203 Science	Sink Faucet		X	5:59	1.46	1030	
77	HS-02-CF-P-77	203 Science	Sink Faucet		X	5:59	2.27	966	
78	HS-02-CF-P-78	203 Science	Sink Faucet		X	5:55	1.37	853	
79	HS-02-CF-P-79	203 Science	Sink Faucet		X	5:55	2.4	959	
80	HS-02-CF-P-80	203 Science	Sink Faucet		X	5:55	3.29	956	
81	HS-02-CF-P-81	203 Science	Sink Faucet		X	5:55	2.13	614	
82	HS-02-CF-P-82	203 Science	Sink Faucet		X	5:55	1.37	809	
83	HS-02-CF-P-83	203 Science	Sink Faucet		X	5:55	1.35	713	
84	HS-02-CF-P-84	203 Science	Sink Faucet		X	5:55	1.67	957	
85	HS-02-CF-P-85	203 Science	Sink Faucet		X	5:58	1.72	876	
86	HS-02-CF-P-86	205 Prep	Sink Faucet		X	5:58	3.43	1040	
87	HS-02-CF-P-87	207 Science	Sink Faucet		X	5:55	8.49	152	
88	HS-02-CF-P-88	207 Science	Sink Faucet		X	5:58	12.1	414	
89	HS-02-CF-P-89	207 Science	Sink Faucet		X	5:58	2.66	60.9	
90	HS-02-CF-P-90	207 Science	Sink Faucet		X	5:59	16.2	32.1	Science classroom - Non-potable water table affixed
91	HS-02-CF-P-91	207 Science	Sink Faucet		X	5:59	18	282	Science classroom - Non-potable water table affixed
92	HS-02-CF-P-92	207 Science	Sink Faucet		X	5:59	17.6	29.8	Science classroom - Non-potable water table affixed
93	HS-02-CF-P-93	207 Science	Sink Faucet		X	5:59	17.8	106	Science classroom - Non-potable water table affixed
94	HS-02-CF-P-94	207 Science	Sink Faucet		X	5:59	15.7	51.5	Science classroom - Non-potable water table affixed
95	HS-02-CF-P-95	207 Science	Sink Faucet		X	5:59	11.5	292	
96	HS-02-BF-P-96	215 Girl's Restroom	Bathroom Faucet		X	6:01	2.11	448	
97	HS-02-BF-P-97	215 Girl's Restroom	Bathroom Faucet		X	6:01	4.43	381	
98	HS-02-BF-P-98	215 Girl's Restroom	Bathroom Faucet		X	6:01	2.94	379	
99	HS-02-BF-P-99	Faculty Restroom	Bathroom Faucet		X	6:03	ND	947	
100	HS-02-BF-P-100	217 Boy's Restroom	Bathroom Faucet		X	6:04	2.96	562	
101	HS-02-BF-P-101	217 Boy's Restroom	Bathroom Faucet		X	6:04	2.18	511	
102	HS-02-BF-P-102	217 Boy's Restroom	Bathroom Faucet		X	6:04	2.93	449	
103	HS-02-CF-P-103	208	Sink Faucet		X	6:08	3.25	190	
104	HS-02-CF-P-104	211a Prep	Sink Faucet		X	6:07	1.37	814	
105	HS-02-CF-P-105	211 Science	Sink Faucet		X	6:08	1.5	767	
106	HS-02-CF-P-106	211 Science	Sink Faucet		X	6:08	1.32	811	
107	HS-02-CF-P-107	211 Science	Sink Faucet		X	6:08	1.38	957	
108	HS-02-CF-P-108	211 Science	Sink Faucet		X	6:08	1.91	780	
109	HS-02-CF-P-109	211 Science	Sink Faucet		X	6:08	1.32	918	
110	HS-02-CF-P-110	211 Science	Sink Faucet		X	6:08	2.32	1290	
111	HS-02-CF-P-111	211 Science	Sink Faucet		X	6:08	1.78	1210	
112	HS-02-CF-P-112	211 Science	Sink Faucet		X	6:08	3.89	520	
113	HS-02-CF-P-113	211 Science	Sink Faucet		X	6:08	2.84	531	
114	HS-02-CF-P-114	213a Science Prep	Sink Faucet		X	6:12	19.5	565	Science classroom - Non-potable water table affixed
115	HS-02-CF-P-115	213 Science	Sink Faucet		X	6:12	10	117	
116	HS-02-CF-P-116	213 Science	Sink Faucet		X	6:12	2.47	394	
117	HS-02-CF-P-117	213 Science	Sink Faucet		X	6:12	1.37	700	
118	HS-02-CF-P-118	213 Science	Sink Faucet		X	6:14	4.43	422	

119	HS-02-CF-P-119	214 Science	Sink Faucet			X	5:27	1.68	268	
120	HS-01-SF-P-120	Faculty Sink	Sink Faucet			X	5:27	1.55	681	
121	HS-01-8F-P-121	Faculty Sink	Sink Faucet			X	5:43	ND	741	
122	HS-01-KF-P-122	Kitchen Faucet sink	Sink Faucet			X	5:47	2.64	697	
123	HS-01-DW-P-123	118 Boys Fountain	Fountain			X	6:05	103	327	Taken out of service after Initial results
	HS-01-DW-P-123RS	118 Boys Fountain	Fountain			X	6:30	3.9	-	Resample - attached bottle filler - lead only water
	HS-01-DW-P-123RS	118 Boys Fountain	Fountain			X	6:32	3	-	Resample - Drinking faucet - lead only
124	HS-02-DW-P-124	2nd Floor Fountain	Fountain			X	6:08	3.47	248	
125	HS-02-CF-P-125	211				X	6:23	3.82	697	
126	HS-01-SF-P-126	Loading Dock	Utility Sink			X	6:23	0.59	594	