

**A NOTICE TO PARENTS, GUARDIANS, and STAFF**  
**Hoosic Valley Central School District**  
**Lead Testing of School Drinking Water**

11/20/2020

Safe and healthy school environments can foster healthy and successful children. To protect public health, the Public Health Law and New York State Health Department (NYSDOH) regulations require that all public schools and boards of cooperative educational services (BOCES) test lead levels in water from every outlet that is being used, or could potentially be used, for drinking or cooking. If lead is found at any water outlet at levels above 15 parts per billion (ppb), which is equal to 15 micrograms per liter ( $\mu\text{g/L}$ ), the NYSDOH requires that the school take action to reduce the exposure to lead.

**What is first draw testing of school drinking water for lead?**

The “on-again, off-again” nature of water use at most schools can raise lead levels in school drinking water. Water that remains in pipes overnight, over a weekend, or over vacation periods stays in contact with lead pipes or lead solder and, as a result, could contain higher levels of lead. This is why schools are required to collect a sample after the water has been sitting in the plumbing system for a certain period of time. This “first draw” sample is likely to show higher levels of lead for that outlet than what you would see if you sampled after using the water continuously. However, even if the first draw sample does not reflect what you would see with continuous usage, it is still important because it can identify outlets that have elevated lead levels.

**What are the results of the first draw testing?**

High School Elevated Lead Level Results

30a Band/Chorus, Sink Faucet, (39.4 PPB) – Sign Posted, Hand Washing Only

45 Concession, Sink Faucet, (46.7 PPB) – Sign Posted, Hand Washing Only

35b Boy's Restroom, Bathroom Faucet, (31.7 PPB) – Sign Posted, Hand Washing Only

Classroom 109, Sink Faucet, (15.4 PPB) – Sign Posted, Hand Washing Only

Elementary School Elevated Lead Level Results

Kitchen, Sink Faucet, (36.6 PPB) – Sign Posted, Hand Washing Only

**What is being done in response to the results?**

Outlets that tested with lead levels above the action level (15 ppb) were removed from service, unless an outlet is a sink faucet needed for handwashing. In that case, a sign was posted at the outlet indicating that the sink is not to be used for drinking. Outlets that tested below the action level remain in service with no restrictions.

**What are the health effects of lead?**

Lead is a metal that can harm children and adults when it gets into their bodies. Lead is a known neurotoxin, particularly harmful to the developing brain and nervous system of children under 6 years old. Lead can harm a young child's growth, behavior, and ability to learn. Lead exposure during pregnancy may contribute to low birth weight and developmental delays in infants. There are many sources of lead exposure in the environment, and it is important to reduce all lead exposures as much as possible. Water testing helps identify and correct possible sources of lead that contribute to exposure from drinking water.

## **What are the other sources of lead exposure?**

Lead is a metal that has been used for centuries for many purposes, resulting in widespread distribution in the environment. Major sources of lead exposure include lead-based paint in older housing, and lead that built up over decades in soil and dust due to historical use of lead in gasoline, paint, and manufacturing. Lead can also be found in a number of consumer products, including certain types of pottery, pewter, brass fixtures, foods, plumbing materials, and cosmetics. Lead seldom occurs naturally in water supplies but drinking water could become a possible source of lead exposure if the building's plumbing contains lead. The primary source of lead exposure for most children with elevated blood-lead levels is lead-based paint.

## **Should your child be tested for lead?**

The risk to an individual child from past exposure to elevated lead in drinking water depends on many factors; for example, a child's age, weight, amount of water consumed, and the amount of lead in the water. Children may also be exposed to other significant sources of lead including paint, soil and dust. Since blood lead testing is the only way to determine a child's blood lead level, parents should discuss their child's health history with their child's physician to determine if blood lead testing is appropriate. Pregnant women or women of childbearing age should also consider discussing this matter with their physician.

## **Additional Resources**

**For more information regarding the testing program or sampling results,** contact *Matt Waryas* at (518)753-4458 x1504, or go to our school website: [www.hoosicvalley.k12.ny.us](http://www.hoosicvalley.k12.ny.us)

**For information about lead in school drinking water, go to:**

[http://www.health.ny.gov/environmental/water/drinking/lead/lead\\_testing\\_of\\_school\\_drinking\\_water.htm](http://www.health.ny.gov/environmental/water/drinking/lead/lead_testing_of_school_drinking_water.htm)

<http://www.p12.nysed.gov/facplan/LeadTestinginSchoolDrinkingWater.html>

**For information about NYS Department of Health Lead Poisoning Prevention, go to:**

<http://www.health.ny.gov/environmental/lead/>

**For more information on blood lead testing and ways to reduce your child's risk of exposure to lead, see "What Your Child's Blood Lead Test Means":**

<http://www.health.ny.gov/publications/2526/> (available in ten languages).

**CLIENT INFORMATION**

<b>Name:</b> Hoosic Valley Central School District
<b>Address:</b> 2 Pleasant Ave, Schaghticoke, NY 12154
<b>Client Rep:</b> Marc Iorio (518) 753-4458 ext 1502

<b>Date of Sampling:</b>
<b>Samples Taken By:</b>
<b>District Staff:</b>

**SCHOOL/PROJECT INFORMATION**

<b>BLDG NO./NAME:</b> District Office
<b>BLDG ADDRESS:</b> 2 Pleasant Ave, Schaghticoke, NY 12154
<b>CONTACT NAME &amp; NUMBER:</b> Matthew Waryas 518-708-3970

<b>(1) Yr. Built:</b>	<b>(2) Yr 1st Add:</b>	<b>(3) Yr 2nd Add:</b>	<b>(4) Yr 1st Mod:</b>	<b>(5) Yr. 2nd Mod:</b>
1959				

**SAMPLE DATA**

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	DO-01-BF-P-01	Bathroom by Business Admin	Bathroom Faucet			4.4							
2	DO-01-BF-P-02	Bathroom by Supt. Office	Bathroom Faucet			1.4							
3	DO-01-BF-P-03	Supt. Bathroom	Bathroom Faucet			5.2							
4	DO-01-SF-P-04	Board Room Storage	Sink Faucet			10.4							
5	DO-01-SF-P-05	Trans. Breakroom	Sink Faucet			2.7							
6	DO-01-BF-P-06	Trans. Breakroom Mens	Bathroom Faucet			<1							
7	DO-01-BF-P-07	Trans. Breakroom Mens	Bathroom Faucet			1.4							
8	DO-01-BF-P-08	Trans. Breakroom Womens	Bathroom Faucet			1.7							
9	DO-01-DW-P-09	Trans Bathroom Fountain	Water Fountain			<1							
10	DO-01-DW-P-10	DO Lobby Fountain	Water Fountain			<1							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO<sub>3</sub>@ pH by lab

**CHAIN OF CUSTODY**

<b>Relinquished By:</b>	<b>Received By:</b>	<b>Time:</b>	<b>Date:</b>

**INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)**

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

Page 1 of 2

CLIENT INFORMATION

Name: Hoosic Valley Central School District
Address: 2 Pleasant Ave, Schaghticoke, NY 12154
Client Rep: Marc Iorio (518) 753-4458 ext 1502

Date of Sampling:
Samples Taken By:
Samples Taken By:
District Staff:
District Staff:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Jr./Sr. High School
BLDG ADDRESS: 1758 Route 67, Schaghticoke, NY 12154
CONTACT NAME & NUMBERS: Matthew Waryas 518-708-3970

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	HS-01-SF-P-01	131 Guidance	Sink Faucet			3.3							
2	HS-01-NF-P-02	29 Nurse	Sink Faucet			2.2							
3	HS-01-CF-P-03	30a Band/Chorus	Sink Faucet			39.4							
4	HS-01-CF-P-04	24 Technology	Sink Faucet				Mixing Valve						
5	HS-01-CF-P-05	24 Technology	Sink Faucet				Mixing Valve						
6	HS-01-CF-P-06	24 Technology	Sink Faucet				Mixing Valve						
7	HS-01-CF-P-07	24 Technology	Sink Faucet				Mixing Valve						
8	HS-01-BF-P-08	57 Coaches Bathroom Right	Bathroom Faucet				Mixing Valve						
9	HS-01-BF-P-09	55 Coaches Bathroom Left	Bathroom Faucet				Mixing Valve						
10	HS-01-DW-P-10	55/57 Fountain Left	Water Fountain				OFF-Covid						
11	HS-01-DW-P-11	55/57 Fountains Right	Water Fountain				OFF-Covid						
12	HS-01-DW-P-12	55/57 Bottle Filler	Bottle Filler			1.3							
13	HS-01-BF-P-13	Restroom by 18	Bathroom Faucet				Mixing Valve						
14	HS-01-CF-P-14	Classroom 18	Sink Faucet			1.9							
15	HS-01-CF-P-15	Classroom 16	Sink Faucet			1.8							
16	HS-01-IM-P-16	47a	Ice Machine			<1							
17	HS-01-SF-P-17	45 Concession	Sink Faucet			4.9							
18	HS-01-SF-P-18	45 Concession	Sink Faucet			46.7							
19	HS-01-DW-P-19	Between Locker Rms	Water Fountain				OFF-Covid						
20	HS-01-DW-P-20	Between Locker Rms	Bottle Filler			<1							
21	HS-01-CF-P-21	17a	Sink Faucet			3.2							
22	HS-01-DW-P-22	Fountain by Gym Doors	Water Fountain				OFF-Covid						
23	HS-01-DW-P-23	Fountain by Gym Doors	Bottle Filler			<1							
24	HS-01-BF-P-24	35b Boy's Restroom	Bathroom Faucet			1.4							
25	HS-01-BF-P-25	35b Boy's Restroom	Bathroom Faucet			31.7							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	



POTABLE WATER SAMPLING FOR LEAD CONCENTRATION SAMPLE COLLECTION FORM

Appendix D

CLIENT INFORMATION

Name: Hoosic Valley Central School District
Address: 2 Pleasant Ave, Schaghticoke, NY 12154
Client Rep: Marc Iorio (518) 753-4458 ext 1502

Date of Sampling:
Samples Taken By:
Samples Taken By:
District Staff:
District Staff:

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Elementary School
BLDG ADDRESS: 22 Pleasant Ave, Schaghticoke, NY 12154
CONTACT NAME & NUMBERS: Matthew Waryas 518-708-3970

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1959				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
1	ES-01-CF-P-01	52	Sink Faucet			1.1							
2	ES-01-DW-P-02	52	Bubbler				OFF-Covid						
3	ES-01-CF-P-03	50	Sink Faucet			4.4							
4	ES-01-CF-P-04	50	Sink Faucet			<1							
5	ES-01-DW-P-05	50	Bubbler				OFF-Covid						
6	ES-01-BF-P-06	Corridor by 44	Bathroom Faucet			2.1							
7	ES-01-BF-P-07	Corridor by 49	Bathroom Faucet			1							
8	ES-01-CF-P-08	51	Sink Faucet			9.1							
9	ES-01-DW-P-09	51	Bubbler			7							
10	ES-01-CF-P-10	55	Sink Faucet			4							
11	ES-01-DW-P-11	55	Bubbler				OFF-Covid						
12	ES-01-CF-P-12	57	Sink Faucet			10.3							
13	ES-01-DW-P-13	57	Bubbler			3							
14	ES-01-CF-P-14	59	Sink Faucet			8.6							
15	ES-01-DW-P-15	59	Bubbler				OFF-Covid						
16	ES-01-CF-P-16	61	Sink Faucet			<1							
17	ES-01-DW-P-17	61	Bubbler				OFF-Covid						
18	ES-01-CF-P-18	63	Sink Faucet			10.8							
19	ES-01-DW-P-19	63	Bubbler				OFF-Covid						
20	ES-01-CF-P-20	65	Sink Faucet			1.8							
21	ES-01-DW-P-21	65	Bubbler				OFF-Covid						
22	ES-01-CF-P-22	67	Sink Faucet			<1							
23	ES-01-DW-P-23	67	Bubbler			<1							
24	ES-01-CF-P-24	69	Sink Faucet			<1							
25	ES-01-DW-P-25	69	Bubbler			<1							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

CLIENT INFORMATION

Name: Hoosic Valley Central School District  
 Address: 2 Pleasant Ave, Schaghticoke, NY 12154  
 Client Rep: Marc Iorio (518) 753-4458 ext 1502

SCHOOL/PROJECT INFORMATION

BLDG NO./NAME: Elementary School  
 BLDG ADDRESS: 22 Pleasant Ave, Schaghticoke, NY 12154  
 CONTACT NAME & NUMBERS: Matthew Waryas 518-708-3970

(1) Yr. Built	(2) Yr 1st Add:	(3) Yr 2nd Add:	(4) Yr 1st Mod:	(5) Yr. 2nd Mod:
1959				

Date of Sampling:  
 Samples Taken By:  
 Samples Taken By:  
 District Staff:  
 District Staff:

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
26	ES-01-CF-P-26	66	Sink Faucet			<1							
27	ES-01-DW-P-27	66	Bubbler			<1							
28	ES-01-CF-P-28	64	Sink Faucet			<1							
29	ES-01-DW-P-29	64	Bubbler			<1							
30	ES-01-BF-P-30	Boy's Restroom 62	Bathroom Faucet			<1							
31	ES-01-BF-P-31	Girl's Restroom 62	Bathroom Faucet			1.7							
32	ES-01-CF-P-32	60	Sink Faucet			9							
33	ES-01-DW-P-33	60	Bubbler			3.1							
34	ES-01-CF-P-34	58	Sink Faucet			9.4							
35	ES-01-DW-P-35	58	Bubbler				OFF-Covid						
36	ES-01-CF-P-36	56	Sink Faucet			10.8							
37	ES-01-DW-P-37	56	Bubbler			2.8							
38	ES-01-BF-P-38	Boiler Restroom	Bathroom Faucet			<1							
39	ES-01-DW-P-39	Corridor Boiler	Water Fountain			1.6							
40	ES-01-DW-P-40	Boy's Locker Room	Water Fountain			1.8							
41	ES-01-BF-P-41	Boy's Locker Room	Bathroom Faucet			1.2							
42	ES-01-DW-P-42	Girl's Locker Room	Water Fountain				OFF						
43	ES-01-BF-P-43	Girl's Locker Room	Bathroom Faucet			4.9							
44	ES-01-CF-P-44	47	Sink Faucet			<1							
45	ES-01-DW-P-45	47	Bubbler			<1							
46	ES-01-CF-P-46	45	Sink Faucet			<1							
47	ES-01-DW-P-47	45	Bubbler			<1							
48	ES-01-CF-P-48	43	Sink Faucet			1.4							
49	ES-01-DW-P-49	43	Bubbler			4.4							
50	ES-01-BF-P-50	Men's Restroom	Bathroom Faucet			<1							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

Relinquished By:	Received By:	Time:	Date:

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab:

Contact:

Comments: Provide Laboratory Data Report (LDR) and Chain of Custody

CLIENT INFORMATION

<b>Name:</b> Hoosic Valley Central School District
<b>Address:</b> 2 Pleasant Ave, Schaghticoke, NY 12154
<b>Client Rep:</b> Marc Iorio (518) 753-4458 ext 1502

SCHOOL/PROJECT INFORMATION

<b>BLDG NO./NAME:</b> Elementary School
<b>BLDG ADDRESS:</b> 22 Pleasant Ave, Schaghticoke, NY 12154
<b>CONTACT NAME &amp; NUMBERS:</b> Matthew Waryas 518-708-3970

<b>Date of Sampling:</b>
<b>Samples Taken By:</b>
<b>Samples Taken By:</b>
<b>District Staff:</b>
<b>District Staff:</b>

<b>(1) Yr. Built</b>	<b>(2) Yr 1st Add:</b>	<b>(3) Yr 2nd Add:</b>	<b>(4) Yr 1st Mod:</b>	<b>(5) Yr. 2nd Mod:</b>
1959				

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
51	ES-01-BF-P-51	Men's Restroom	Bathroom Faucet			<1							
52	ES-01-BF-P-52	Men's Restroom	Bathroom Faucet			1							
53	ES-01-BF-P-53	Women's Restroom	Bathroom Faucet			1.9							
54	ES-01-BF-P-54	Women's Restroom	Bathroom Faucet			1.1							
55	ES-01-BF-P-55	Women's Restroom	Bathroom Faucet			1.2							
56	ES-01-BF-P-56	Women's Restroom	Bathroom Faucet			1.3							
57	ES-01-CF-P-57	41	Sink Faucet			1.7							
58	ES-01-DW-P-58	41	Bubbler				OFF-Covid						
59	ES-01-CF-P-59	39	Sink Faucet			<1							
60	ES-01-DW-P-60	39	Bubbler			<1							
61	ES-01-DW-P-61	Corridor 39	Water Cooler				OFF-Covid						
62	ES-01-DW-P-62	Corridor 39	Water Cooler				OFF-Covid						
63	ES-01-BF-P-63	Main Office Men's Restroom	Bathroom Faucet			<1							
64	ES-01-BF-P-64	Main Office Women's Rest	Bathroom Faucet			<1							
65	ES-01-CF-P-65	21 Library	Sink Faucet			1.7							
66	ES-01-BF-P-66	Faculty Restroom Left	Bathroom Faucet				Mixing Valve						
67	ES-01-SF-P-67	Faculty Restroom Right	Bathroom Faucet				Mixing Valve						
68	ES-01-SF-P-68	17 TLC	Sink Faucet			4.4							
69	ES-01-DW-P-69	17 TLC	Bubbler			3.4							
70	ES-01-CF-P-71	15	Sink Faucet			8.8							
71	ES-01-DW-P-71	15	Bubbler				OFF-Covid						
72	ES-01-CF-P-72	13	Sink Faucet			4.6							
73	ES-01-DW-P-73	13	Bubbler				OFF-Covid						
74	ES-01-CF-P-74	11	Sink Faucet			1.7							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

<b>Relinquished By:</b>	<b>Received By:</b>	<b>Time:</b>	<b>Date:</b>

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE
Contact:
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody



CLIENT INFORMANTION

<b>Name:</b> Hoosic Valley Central School District				
<b>Address:</b> 2 Pleasant Ave, Schaghticoke, NY 12154				
<b>Client Rep:</b> Marc Iorio (518) 753-4458 ext 1502				
<b>SCHOOL/PROJECT INFORMATION</b>				
<b>BLDG NO./NAME:</b> Elementary School				
<b>BLDG ADDRESS:</b> 22 Pleasant Ave, Schaghticoke, NY 12154				
<b>CONTACT NAME &amp; NUMBERS:</b> Matthew Waryas 518-708-3970				
<b>(1) Yr. Built</b>	<b>(2) Yr 1st Add:</b>	<b>(3) Yr 2nd Add:</b>	<b>(4) Yr 1st Mod:</b>	<b>(5) Yr. 2nd Mod:</b>
1959				

<b>Date of Sampling:</b>
<b>Samples Taken By:</b>
<b>Samples Taken By:</b>
<b>District Staff:</b>
<b>District Staff:</b>

SAMPLE DATA

Sample Description ID (ID must match container label)				Outlet Information									
Lab Sample #	BOCES Sample #	Location	Outlet Description	Outlet Make & Model	Construct. Date	First Draw	Time of Collection (24hr)	30 Second Flush Draw	Time of Collection (24hr)	Service Connection Draw	Time of Collection (24hr)	Water Main Draw	Time of Collection (24hr)
75	ES-01-DW-P-75	11	Bubbler				OFF-Covid						
76	ES-01-BF-P-76	11	Bathroom Faucet			<1							
77	ES-01-CF-P-77	9	Sink Faucet			6.1							
78	ES-01-DW-P-78	9	Bubbler				OFF-Covid						
79	ES-01-CF-P-79	7	Sink Faucet			7							
80	ES-01-DW-P-80	7	Bubbler				OFF-Covid						
81	ES-01-CF-P-81	6	Sink Faucet				OFF						
82	ES-01-DW-P-82	6	Bubbler				OFF-Covid						
83	ES-01-CF-P-83	5	Sink Faucet			4.4							
84	ES-01-DW-P-84	5	Bubbler				OFF-Covid						
85	ES-01-BF-P-85	5	Bathroom Faucet			8.4							
86	ES-01-CF-P-86	3	Sink Faucet			4.7							
87	ES-01-DW-P-87	3	Bubbler				OFF-Covid						
88	ES-01-BF-P-88	3	Bathroom Faucet			4.6							
89	ES-01-CF-P-89	1	Sink Faucet			3.6							
90	ES-01-DW-P-90	1	Bubbler				OFF-Covid						
91	ES-01-CF-P-91	2	Sink Faucet			5.4							
92	ES-01-DW-P-92	2	Bubbler				OFF-Covid						
93	ES-01-BF-P-93	2	Bathroom Faucet				OFF						
94	ES-01-SF-P-94	4	Sink Faucet			7.1							
95	ES-01-DW-P-95	4	Bubbler				OFF-Covid						
96	ES-01-BF-P-96	4	Bathroom Faucet			6.7							
97	ES-01-CF-P-97	8	Sink Faucet			8							
98	ES-01-DW-P-98	8	Bubbler				OFF-Covid						
99	ES-01-CF-P-99	10	Sink Faucet			11.2							

All containers are pre-cleaned/pre-certified 250ml plastic bottles and will be preserved w/HNO3@ pH by lab

CHAIN OF CUSTODY

<b>Relinquished By:</b>	<b>Received By:</b>	<b>Time:</b>	<b>Date:</b>

INSTRUCTIONS TO THE LABORATORY - Analyze all samples for both lead and copper (Pb and Cu)

Lab: PACE	
Contact:	
Comments: Provide Laboratory Data Report (LDR) and Chain of Custody	

